

Franklin-Simpson Planning & Zoning Commission

P.O. Box 1025 * Franklin, KY 42135-1025 * Phone: (270) 586-3356 * Fax: (270) 586-3596

Building Inspector – Joe Perry

Chief Electrical Inspector – Robert W. Matthews

The Kentucky Department of Housing requires a plan review for HVAC permits on commercial projects. In order for me to perform the plan review I will need the following list furnished prior to a permit application to the state. This is to be furnished with a floor plan showing location, routing, etc with notes.

1. A manual "J" cover sheet containing a summary of the manual J output. (minimum)
2. Unit size(s) and CFM specifications and make up air requirements.
3. Supply duct material, size and type.
4. Return duct material, size, and type.
5. Supply and return grill size(s) and location.
6. Insulation values and type.
7. Bath fans location and sizing.
8. Dryer vent location and sizing.